



DATE: 2/7/2024

TO: PROSPECTIVE BIDDERS

SUBJECT: **ADDENDUM NO. 1** TO THE BIDDING DOCUMENTS FOR

ELECTRICAL CONTRACT BID

RIALTO SQUARE THEATRE

102 N CHICAGO ST

JOLIET, IL 60432

This addendum forms a part of the bidding and contract documents and modifies the original bidding documents, dated February 2nd, 2024.

REQUEST FOR INFORMATION:

1. On page 18, "Project Description", the instructions call for the following: Electrical Engineer will develop an electrical one-line schematic drawing of the existing electrical. Can a SKM Systems Analysis be submitted in place of a One Line Diagram?

Response: Yes, subject to compliance with all applicable local municipal code requirements, all bidders are authorized to propose either option; SKM study or One Line schematic.